

ARIZONA DEPARTMENT OF WEIGHTS AND MEASURES

Michelle Wilson August 1, 2013

Agenda

- AZDWM regulation of fueling facilities
- Vapor Recovery
- Fuel Quality
- Inspection Findings

Our mission:

"To Protect the Integrity of Arizona's Marketplace By Ensuring that Equity and Accuracy are Preserved In Commerce Through Fair and Equitable Regulation and the Effective Communication of Weight and Measurement Standards."


At Motor Fueling Stations....

- License all metering devices statewide and vapor recovery devices in Areas A and B
- License businesses and individuals that test, install, service or repair
- Conduct inspections:
 - Pricing/signage
 - Pump accuracy
 - Fuel Quality
 - Vapor recovery
 - Complaints
- Arizona Revised Statutes (ARS) Title 41, Chapter 15,
 Arizona Administrative Code (AAC), Title 20,
 Chapter 2


Vapor Recovery



Stage I



Stage II



Vapor Recovery Requirements

- ARS 41-2132, AAC R20-2-901 through 912
- General requirements:
 - Authority to Construct (ATC) permit to install/modify
 - Adequate training/written instruction to operator
 - Repair, replace, or modify worn/ineffective equipment
 - Ensure proper operation
 - Annual testing of Stage II equipment

Vapor Recovery Violations

Failure to maintain equipment





Vapor Recovery Violations, cont...



Failure to maintain equipment





Vapor Recovery Violations, cont...

Failure to apply for Authority to Construct Permit

Not performing daily inspections and/or falsifying daily inspections


Not maintaining maintenance log

Failure to conduct annual test

Fuel Quality Requirements

- ARS Title 41, Articles 3 and 6, and AAC Title 20, Article 7
- General requirements fueling station owners:
 - Meet fuel standard requirements
 - Product Transfer Documentation
 - Tank/Dispenser labeling
 - Dispenser compatibility

Fuel Quality



Fuel Quality Inspections

750 inspections2070 tests550 sent to laboratory

- Water
- Octane, ethanol
- PTDs
- Dispenser compatibility
- Skimmers
- Dispenser/tank label
- Samples to lab ASTM standards



Fuel Quality Violations

- Dispenser Compatibility
 - NTEP approved (http://www.ncwm.net/certificates)

Water in fuel

Fuel does not meetASTM standards



Fuel Quality Violations, cont...




- Missing octane, ethanol labels
- Missing tank labels
- Selling lower octane than advertised
- Missing PTDs

Other Common Violations

Pricing displays not legible





Meter jump Meter creep Calibration

Other Violations, cont....



General maintenance/ safety issues




Future Changes

Decommissioning of Stage 2 Vapor Recovery (Area A)


Figure 1

Phase I, Phase II & ORVR Vapor Recovery Operations at California Service Stations



Source: ARB Response to US EPA ORVR Widespread Use Rule (CARB Sept. 2011)

Incompatibility between ORVR and Stage II systems



EPA widespread use determination

- Final rule May 16, 2012 (77 FR 28772)
- Guidance document on removing Stage II from State Implementation Plan August 7,2012
- States may choose (<u>but are not required</u>) to remove Stage II from their SIP

Stage II Vapor Recovery

Stakeholder Meeting November 2012

Action	Anticipated Date
Prepare and submit the SIP revision removing the Stage II	January to December 2013
program from the SIP	
Modify the applicable statute(s) requiring the use of Stage II	January to September 2014
vapor recovery equipment	
EPA Review/Approval of SIP	January 2014 to July 2015
Modify rules to reflect decommissioning of Stage II and	January 2014 to July 2015
requirements for remaining Stage I systems	
Decommission Stage II equipment	January 1, 2016 to December 31, 2017

Summary of Stage II program changes on website:

http://www.azdwm.gov/BUSINESS/VaporRecovery/StageIIProgramChanges/tabid/362/Default.aspx



Michelle Wilson

602-771-4933 mwilson@azdwm.gov